

ROUTING AND RECORD SHEET

SUBJECT: (Optional)

Vehicle Parking Spaces, North and South Loading Docks, New HQ Building

FROM:

Chief, Safety Division, OMS

EXTENSION

NO.

DATE

20 January 1988

TO: (Officer designation, room number, and building)

DATE

RECEIVED

FORWARDED

OFFICER'S INITIALS

COMMENTS (Number each comment to show from whom to whom. Draw a line across column after each comment.)

1. Chief, New Building
Project Office, OL
1 J 45, HQ

2.

3.

4.

5.

6.

7.

8.

9.

10.

11.

12.

13.

14.

15.

Please make
a copy of this for
me.
Done
1/24

20 January 1988

MEMORANDUM FOR: Chief, New Building Project Office
Office of Logistics

FROM:

Chief, Safety Division
Office of Medical Services

SUBJECT: Vehicle Parking Spaces, North and South
Loading Docks, New Headquarters Building

1. Bid Package 2, Drawing 2-C3-5, indicates that there are to be vehicle parking spaces along the East wall of the New Building at both the North and South Loading Docks. These spaces must be deleted and redesignated as a fire lane. The fire lane shall be lettered and striped with yellow paint (see attached sketch). The reason for this change is to allow access by the fire department to the sprinkler connections along the East wall.

2. If there are any questions, please contact
Chief, Fire Protection
Engineering Branch, Safety Division, on extension

Attachments

Page Denied

Next 1 Page(s) In Document Denied